



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 26-04-2023

Test No: 1387

Weather: Sunny

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 9:00 AM	Sampling Time: 9:30 AM	Sampling Time: 9:40 AM	Sampling Time: 11:10 AM	Sampling Time: 11:25 AM	Sampling Time: 11:36 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.6	28.5	28/2	27.7
2	pH		day	6.5-8.5				8.14	8.05	7.98	7.94
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	63.5	15.3	15.1	1.47	0.54	0.21
4	Color	pt-co	day	15	Portable analyser-AQ3700			95	7	3	0
5	Suspended Solid	mg/L	day	...				54	14	14	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Calcium	mg/L	Once a week	75	WTW PhotoFlex Turb						
8	ORP	mv	Once a week	...	WTW pH/ ION 3310						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			440	360		
Remark:											