



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 10-07-2023

Test No: 1462

Weather: Cloudy

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water							
						Sampling Time: 12:50 PM	Sampling Time: 10:10 AM	Sampling Time: 12:00 PM	Sampling Time: 12:35 PM	Sampling Time: 12:40 PM	Sampling Time: 12:45 PM							
1	Temperature	°C	day	20-30	Portable analyser-ST300			28.2	28	27.2	27.2							
2	pH		day	6.5-8.5				8.21	8.07	7.97	7.99							
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	124	34.9	34.8	1.98	0.39	0.32							
4	Color	pt-co	day	15	Portable analyser-AQ3700			199	35	9	4							
5	Suspended Solid	mg/L	day	...				129	36	36	3	0	0					
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable							
7	Total Aluminium	mg/L	Once a week	0.2	Eriochrome Cyanine R Method1							0.029						
8	Total Iron	mg/L	Once a week	0.3	USEPA 1 FerroVer Method											0.05		
9	Total residual chlorine	mg/L	Twice a week	0.2	USEPA DPD Method1													
10	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	40	200											
Remark:																		