



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 14-08-2023

Test No: 1497

Weather: Cloudy

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water	
						Sampling Time: 09:20 AM	Sampling Time: 09:30 AM	Sampling Time: 10:10 AM	Sampling Time: 10:50 AM	Sampling Time: 11:00 AM	Sampling Time: 11:10 AM	
1	Temperature	°C	day	20-30	Portable analyser-ST300	/		25.7	25.5	25.5	25.4	
2	pH		day	6.5-8.5				8.63	8.27	8.29	8.09	
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	230	41.5	38.4	1.88	0.27	0.09	
4	Color	pt-co	day	15	Portable analyser-AQ3700	/		244	14	1	0	
5	Suspended Solid	mg/L	day	...				229	40	40	2	0
6	Taste and Odour		day	Odorless	Manual	/		Dirty Smell	Dirty Smell	No Objectionable	No Objectionable	
7	Total Aluminium	mg/L	Once a week	0.2	Eriochrome Cyanine R Method1			/				
8	Total Manganese	mg/L	Once a week	0.1	1-(2-Pyridylazo)-2-Naphthol PAN	0.006						
9	Total Iron	mg/L	Once a week	0.3	USEPA 1 FerroVer Method	0.06						
10	Total residual chlorine	mg/L	Twice a week	0.2	USEPA DPD Method1	0.29						
11	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	50					50
Remark:												