



# Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

## Daily Water Quality Report of Laboratory

Date of Testing: 21-08-2023

Test No: 1504

Weather: Cloudy

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water	
						Sampling Time: 9:20 AM	Sampling Time: 9:30 AM	Sampling Time: 9:40 AM	Sampling Time: 11:25 AM	Sampling Time: 11:38 AM	Sampling Time: 11:47 AM	
1	Temperature	°C	day	20-30	Portable analyser-ST300			29.6	29.4	29.2	29.2	
2	pH		day	6.5-8.5				7.43	7.39	7.32	7.29	
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	455	56.7	56.1	1.99	0.19	0.14	
4	Color	pt-co	day	15	Portable analyser-AQ3700			349	41	16	14	
5	Suspended Solid	mg/L	day	...				487	57	57	4	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable	
7	Total Aluminium	mg/L	Once a week	0.2	Eriochrome Cyanine R Method1							0.096
8	Total residual chlorine	mg/L	Twice a week	0.2	USEPA DPD Method1							
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	40			50		
Remark:												