



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 15-09-2023

Test No: 1529

Weather: Cloudy

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 09:10 AM	Sampling Time: 09:45 AM	Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 10:48 AM	Sampling Time: 11:00 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			29	29.2	30	28
2	pH		day	6.5-8.5				8.21	8.09	7.98	7.88
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	170	37.2	33	1.98	0.61	0.27
4	Color	pt-co	day	15	Portable analyser-AQ3700			170	27	14	6
5	Suspended Solid	mg/L	day	...				140	28	28	2
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Sulfate	mg/L	Once a week	400	USEPA1 SulfaVer 4 Method2						
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30				
Remark:											