



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 11-10-2023

Test No: 1555

Weather: Cloudy

Sl No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:08 AM	Sampling Time: 10:25 AM	Sampling Time: 11:25 AM	Sampling Time: 11:40 AM	Sampling Time: 11:52 AM	Sampling Time: 12:00 PM
1	Temperature	°C	day	20-30	Portable analyser-ST300			29.2	29.3	30	29.9
2	pH		day	6.5-8.5				8.12	8.02	7.98	7.79
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	144	42	37.9	1.92	0.38	0.29
4	Color	pt-co	day	15	Portable analyser-AQ3700			223	30	15	15
5	Suspended Solid	mg/L	day	...				132	36	36	2
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Calcium	mg/L	Once a week	75	WTW PhotoFlex Turb						
8	ORP	mv	Once a week	...	WTW pH/ ION 3310						
9	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			30	30		
Remark:											