



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 21-10-2023

Test No: 1565

Weather: Sunny

SI No	Test Item	Unit	Frequency	Detection limit (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 11:10 AM	Sampling Time: 09:40 AM	Sampling Time: 09:50 AM	Sampling Time: 10:35 AM	Sampling Time: 10:45 AM	Sampling Time: 10:50 AM
1	Temperature	°C	day	20-30	Portable analyser-ST300			30.6	30.2	29.9	29.7
2	pH		day	6.5-8.5				8.12	7.92	7.88	7.79
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	232	22.4	21.9	1.92	0.27	0.25
4	Color	pt-co	day	15	Portable analyser-AQ3700			163	27	14	13
5	Suspended Solid	mg/L	day	...				272	18	17	2
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Oxygen -Dissolved	mg/L	Once a week	6	Portable analyser-ST300D						
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration	30	30				
Remark:											