



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 26-11-2023

Test No: 1601

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:06 AM	Sampling Time: 10:20 AM	Sampling Time: 10:37 AM	Sampling Time: 11:02 AM	Sampling Time: 11:20 AM	Sampling Time: 11:30 AM
1	Temperature	°C	day	20-30	OHAUS-ST300/ Electrometric			28.2	27.2	28.5	27.5
2	pH		day	6.5-8.5				8.2	8.08	7.95	7.88
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	69.8	11.1	11	1.39	0.49	0.12
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			75	16	13	10
5	Suspended Solid	mg/L	day	...				62	9	9	1
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			30	30		
8	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	166.8	144.3				
Remark:											