



Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

Daily Water Quality Report of Laboratory

Date of Testing: 01-12-2023

Test No: 1606

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 09:40 AM	Sampling Time: 10:00 AM	Sampling Time: 10:30 AM	Sampling Time: 11:05 AM	Sampling Time: 11:20 AM	Sampling Time: 11:30 AM
1	Temperature	°C	day	20-30	OHAUS-ST300/ Electrometric			26.5	26.5	28.2	27.2
2	pH		day	6.5-8.5				8.09	7.98	7.88	7.79
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	92	19.5	19	1.39	0.41	0.13
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			80	18	8	6
5	Suspended Solid	mg/L	day	...				90	10	10	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	Dirty Smell	No Objectionable	No Objectionable
7	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			30	30		
8	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	160.2	150.4				

Remark: