



# Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

## Daily Water Quality Report of Laboratory

Date of Testing: 10-12-2023

Test No: 1615

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water
						Sampling Time: 10:10 AM	Sampling Time: 10:20 AM	Sampling Time: 10:30 AM	Sampling Time: 11:30 AM	Sampling Time: 11:40 AM	Sampling Time: 11:47 AM
1	Temperature	°C	day	20-30	OHAUS-ST300/ Electrometric			25.1	25.8	25.3	25.4
2	pH		day	6.5-8.5				8.03	7.8	7.72	7.68
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	45.7	10.7	10.5	1.68	0.36	0.14
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			74	27	14	7
5	Suspended Solid	mg/L	day	...				46	8	8	1
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable
7	Chloride	ppm	day	150-600	Mercuric Nitrate Titration			30	30		
8	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322	185.2	161.7	40	162.1		
Remark:											