



# Bangabandhu Water Treatment Plant

Khulna WASA, Pathorghata, Rupsha, Khulna-9240

## Daily Water Quality Report of Laboratory

Date of Testing: 05-02-2024

Test No: 1672

Weather: Sunny

Sl No.	Water Quality Parameters	Units	Frequency	BDS for Drinking Water (ECR-1997)	Instrument / Method	River Water	IPR Water	Raw water	Post-sedimentation / Pre-filters Water	Post-filters / Pre-Treated Water	Post-Treated Water		
						Sampling Time: 10:35 AM	Sampling Time: 10:45 AM	Sampling Time: 11:00 AM	Sampling Time: 11:28 AM	Sampling Time: 11:40 AM	Sampling Time: 11:50 AM		
1	Temperature	°C	day	20-30	OHAUS-ST300/ Electrometric			23.9	24	23.5	23.7		
2	pH		day	6.5-8.5				8.13	8.05	7.98	7.88		
3	Turbidity	NTU	day	<1 NTU	WTW PhotoFlex Turb	43.8	13	12.9	1.82	0.38	0.1		
4	Color	pt-co	day	15	Orion AQ3700/ Photometric			85	28	7	0		
5	Suspended Solid	mg/L	day	...				33	10	10	1	0	0
6	Taste and Odour		day	Odorless	Manual			Dirty Smell	No Objectionable	No Objectionable	No Objectionable		
7	Total residual chlorine	mg/L	Twice a week	0.2-0.4	USEPA DPD Method I						0.27		
8	Chloride	ppm	day	150-600	Mercuric Nitrate Titration						30	30	40
9	Total Dissolved Solids	ppm	day	1000	Orion Star™ A222 & A322						201.6	181.8	183.3
Remark:													